

Notice to Porcupine Plain's Water Consumers

Pursuant to Section 44(1) of *The Water Regulations, 2002*, the Town of Porcupine Plain has prepared an annual notice to its water consumers detailing the compliance with water quality standards and sample submissions for 2017.

Pursuant to Section 55 of *The Municipalities Regulations*, the Town of Porcupine Plain has prepared its Annual Waterworks Information document.

A copy of these documents may be requested at the Town Office during regular business hours or by calling the Town Office at 278-2262.

-- posted on Town's website

Town of Porcupine Plain

Annual Notice to Consumers Regarding Drinking-Water Quality and Water-Sample Compliance For the Year Ending December 31, 2017

Introduction

Sask. Environment (SE) requires that, at least once each year, waterworks owners provide notification to consumers of

- the quality of water produced and supplied; and
- information on the performance in submitting samples as required by the Minister's Order for the Porcupine Plain waterworks system

The following is a summary of the Porcupine Plain water-quality data and sample-submission records for 2017. This report was completed on June 1, 2018.

Readers should refer to Saskatchewan Environment's "*Municipal Drinking Water Quality Monitoring Guidelines, November 2002, EPB202*" for more information on minimum sample submission requirements.

Permit requirements for a specific waterworks may require more sampling than outlined in the department's monitoring guidelines. If consumers need more information on the nature and significance of specific water tests, more information is available from:

<http://www.hc-sc.gc.ca/hecs-sesc/water/dwgsup.htm>.

Water Quality Standards

Bacteriological Quality

Parameter / Location	Limit	Number of Samples Required	Number of Samples Submitted	Number of Positive Samples
Total Coliform and Background Bacteria	0 Organisms / 100 ml Less than 200 / 100 ml	52	67	Nil

The owner/operator is responsible to ensure that 100 percent of all bacteriological samples are submitted as required. All waterworks are required to submit samples for bacteriological water quality. The frequency of monitoring depends on the population served by the waterworks.

Water Disinfection – Chlorine Residual in Distribution System for Test Results Submitted with Bacteriological Samples

Parameter	Minimum Limit	Free Chlorine Residual Range	Total Chlorine Residual Range	Number of Tests Required	Number of Tests Submitted	Number with Adequate Chlorine
Chlorine Residual	0.1 mg/L free OR 0.5 mg/L total	.18 to 1.23	.60 to 1.85	52	67	67

Town of Porcupine Plain

Water Disinfection – Free Chlorine Residual for Water Entering Distribution System From Water Treatment Plant Records

Parameter	Limit (mg/L)	Test Level Range	# Tests Performed	# Tests Not Meeting Requirements
Free Chlorine Residual OR Total Chlorine Residual	At least 0.1 ----- At least 0.5	.24 to 1.17 ----- .60 to 1.85	365	0

A minimum of 0.1 milligrams per litre (mg/L) free chlorine residual OR 0.5 mg/L total chlorine residual is required for water entering the distribution system. Tests are normally performed on a daily basis by the waterworks operator and are to be recorded in the operation records. This data includes the number of free chlorine residual tests performed, the overall range of free chlorine residual (highest and lowest recorded values) and the number of tests and percentage of results not meeting the minimum requirement of 0.1 mg/L free chlorine residual.

Turbidity – From Water Treatment Plant Records

Parameter	Limit (NTU)	Test Level Range	Number of Tests Not Meeting Requirements	Maximum Turbidity (NTU)	Number of Tests Required	Number of Tests Performed
Turbidity	1.0	0.10 to .58	0	.58	365	365

Turbidity is a measure of water treatment efficiency. Turbidity measures the “clarity” of the drinking water and is generally reported in Nephelometric Turbidity Units (NTU). All waterworks are required to monitor turbidity at the water treatment plant. The frequency of measurement varies from daily for small systems to continuous for larger waterworks.

All waterworks serving less than 5,000 persons are required to submit water samples for Saskatchewan Environment’s “Chemical Health” category once every two years.

The last sample for “Chemical Health” analysis was submitted in November of 2017. Analysis results indicated that the provincial drinking water quality limits were not exceeded.

Parameter	Maximum Acceptable Concentration (mg / L)	Aesthetic Objective (mg / L)	Sample Results	Exceeds Limit
Aluminum	None set	None set	<6.96	No
Arsenic	<10	None set	1.5	No
Barium	<1000	None set	16.2	No
Boron	<5	None set	.3	No
Cadmium	<5	None set	<.15	No
Chromium	<50	None set	<.19	No
Copper	<1000	1.0	18.9	No
Iron	<.3	0.3	.1	No
Lead	<10	None set	.10	No
Manganese	<.05	0.05	<.01	No
Selenium	<10	None set	<1.13	No
Uranium	<20	None set	1.6	No
Zinc	<5000	5.0	9.6	No
Antimony (ICPMS)	None Set	None Set	<.16	No
Silver (ICPMS)	None Set	None Set	<.20	No

Town of Porcupine Plain

General Chemical

Parameter	Aesthetic Objectives* (mg/L)	Sample Results Average (mg/L)	Number of Samples Required	Number of Samples Submitted
Total Alkalinity	<500	451	1	1
Bicarbonate	No objective	550	1	1
Calcium	No objective	154	1	1
Carbonate	No objective	0	1	1
Chloride	<250	41.9	1	1
Conductivity	<2300	1,267 us/cm	1	1
Hardness	<800	574	1	1
Magnesium	<200	46	1	1
pH	6.5-9.0	7.5	1	1
Sodium	<300	82	1	1
Total dissolved solids	<1,500	1098	1	1
Potassium	No objective	9	1	1
Sulfate	<500.0	215.2	1	1
Hydroxide	No objective	0	1	1
Nitrate	<45	< 0.2	1	1
Fluoride	<1.5	.19	1	1

All waterworks serving less than 5,000 persons are required to submit water samples for Sask. Environment's General Chemical category once every two years if a ground water source.

The last sets of samples for General Chemical analysis were submitted on November 7, 2017. The samples' results indicated that there were no exceedences of the provincial aesthetic objectives for the General Chemical category.

* Objectives apply to certain characteristics of or substances found in water for human consumptive or hygienic use. The presence of these substances will affect the acceptance of water by consumers and/or interfere with the practice of supplying good quality water. Compliance with drinking water aesthetic objectives is not mandatory as these objectives are in the range where they do not constitute a health hazard. The aesthetic objectives for several parameters (including hardness as CaCO₃, magnesium, sodium, and total dissolved solids) consider regional differences in drinking water sources and quality.

More information on water quality and sample-submission performance may be obtained from:

Town of Porcupine Plain
Box 310; Porcupine Plain, Sask.; S0E 1H0
Telephone: 278-2262
Facsimile: 278-3378
E-mail: porcupineplain@sasktel.net